



IRCCOS S.c.a r.l.

Istituto di Ricerca e certificazione per le Costruzioni Sostenibili

Test Laboratory Notified in accordance with Directive 89/106/CEE No. 1994

TEST REPORT

Number:

1994-CPD-RP0813

Issuing date:

2012-06-29

Applicant:

Etem SA

**Iroon Polytechniou str, 1
1908 – Magoula, Attiki (Greece)**

Tested product:

Double vent TT door of E75 series

Trade name: "E75 DOUBLE VENT TT DOOR"

(cf. description)

Executed tests:

Air permeability

Watertightness

Resistance to wind load

Normative References:

EN 14351-1:2006+A1:2010

EN 1026:2000

EN 12207:1999

EN 1027:2000

EN 12208:1999

EN 12211:2000

EN 12210:1999

The report is done up of 24 pages, including any annex, and can be reproduced only integrally.



- 9 Resume of classes assigned on the basis of the results of the tested sample of double vent TT door of E75 series with trade name “E75_DOUBLE VENT DOOR”, according to TR n° 1994-CPD-RP0813, issued on 2012-06-29 to ETEM SA.

| Scheme of the tested sample | Test | Test standard | Classification standard | Obtained Class | Cf. § TR |
|-----------------------------|-------------------------|---------------|-------------------------|----------------|----------|
| | Air permeability | EN 1026:2000 | EN 12207:1999 | class 4 | § 7.2.1 |
| | Watertightness | EN 1027:2000 | EN 12208:1999 | class 7A | § 7.3.1 |
| | Resistance to wind load | EN 12211:2000 | EN 12210:1999 | class C4 | § 7.4.5 |

10 Limitations

This Test Report does not represent either an evaluation the suitability of use or a certificate of product conformity. The results obtained refer exclusively to the samples tested.

Technical Operator

Elisa Farioli

The chairman

for Dott. Italo Meroni

-----End of the Test Report No. 1994-CPD-RP0813-----